

Table 1: List of Pipe Penetrations Eligible for DMP Phase II, Pipe Rehabilitation (CIPP)
NA0009; Lake County Watershed Protrection District

Pipe #	DSID	Unit	Levee Mile	Size	DMP Levee Tier Classification	Material	Structural PACP LoF Grade	Final Recommendation	Recommendation Comments	County	FMAP	In O&M	Permit	Permit No.	Pipe Use	Screening Comments	Phase 2 Eligibility
1	21206	2	0.389	42	Non-Urban Tier 2	CMP	5	CIPP		Lake	Yes	Yes	ABO	11478	Gravity Drainage	To be added to new CIPP Work Order	Yes
2	21208	2	0.478	42	Non-Urban Tier 2	CMP	4.6	CIPP		Lake	Yes	Yes	ABO	11480	Gravity Drainage	To be added to new CIPP Work Order	Yes
3	21215	2	2.842	24	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11481	Gravity Drainage	To be added to new CIPP Work Order	Yes
4	21220	3	0.774	24	Non-Urban Tier 2	CMP	5	CIPP		Lake	Yes	Yes	ABO	11492	Gravity Drainage	To be added to new CIPP Work Order	Yes
5	21221	3	0.928	42	Non-Urban Tier 2	CMP	4.1	CIPP	Pipe has deformation 5%, suggest lining	Lake	Yes	Yes	ABO	11488	Gravity Drainage	To be added to new CIPP Work Order	Yes
6	21222	3	0.992	24	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11488	Gravity Drainage	To be added to new CIPP Work Order	Yes
7	21223	3	1.069	24	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11489	Gravity Drainage	To be added to new CIPP Work Order	Yes
8	21224	3	1.232	36	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11489	Gravity Drainage	To be added to new CIPP Work Order	Yes
9	21237	3	1.234	36	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11489	Gravity Drainage	To be added to new CIPP Work Order	Yes
10	21238	3	1.235	36	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11489	Gravity Drainage	To be added to new CIPP Work Order	Yes
11	21239	3	1.236	36	Non-Urban Tier 2	CMP	4.1	CIPP		Lake	Yes	Yes	ABO	11489	Gravity Drainage	To be added to new CIPP Work Order	Yes
12	21232	5	0.316	36	Non-Urban Tier 2	CMP	4.2	CIPP	Internal pipe coating is failing, small offset joint but could be lined. Offset joint could become worse over time and limit CIPP.	Lake	Yes	Yes	ABO	11507	Gravity Drainage	To be added to new CIPP Work Order	Yes

Note:

- A Pipe penetration that has been replaced by other program(s) (DWR or others) should be excluded from the list.